



Riassunto rapporti analisi 2018

DATA PRELIEVI	05.04.		25.06.		3.09		6.12		Valore tolleranza
	Paese	Nadro	Paese	Nadro	Paese	Nadro	Paese	Nadro	
ANALISI MICROBIOLOGICA									
Germi aerobi mesofili	62 UFC/ml	2 UFC/ml	0 UFC/ml	10 UFC/ml	10 UFC/ml	-	0 UFC/ml	2 UFC/ml	300 UFC/ml
E.coli	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	-	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml
Enterococchi	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	-	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml
ANALISI FISICO CHIMICA									
pH	7.57	7.42	7.1	7.7	---		7.36	7.19	-
Conduttività	65 mcS/cm	62 mcS/cm	67 mcS/cm	103 mcS/cm	---		64 mcS/cm	101 mcS/cm	-
Temperatura	12.7 °C	11.8 °C	11.2 °C	10.2 °C	---		9.8°C	9.3 °C	-
Durezza totale			-	-			< 0.2 mmol/l	0.5 mmol/l	-
Alcalinità			-	-			0.74 mmol/l	0.76 mmol/l	-
Calcio			-	-			< 10 mg/l	13 mg/l	-
Magnesio			-	-			< 5 mg/l	< 5 mg/l	-
Ferro in soluzione			-	-			< 0.1 mg/l	< 0.1 mg/l	0.2 mg/l
Nitriti			-	-			< 0.02 mg/l	< 0.02 mg/l	0.1 mg/l
Nitrati			-	-			4.3 mg/l	7.5 mg/l	40 mg/l
Cloruri			-	-			0.8 mg/l	5.0 mg/l	-
Solfati			-	-			< 10 mg/l	< 10 mg/l	-
Fosfati (P)			-	-			< 0.2 mg/l	< 0.2 mg/l	-
Silicati (SiO2)			-	-			12.82 mg/l	11.5 mg/l	-
Ossidabilità KMnO4			-	-			4.3 mg/l	3.4 mg/l	5 mg/l